

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 7300-0065:149 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Faraday Inc., 805 South Maumee Street, Tecumseh, MI 49286  
Contact: Steven A. Blohm (517) 423-2111

**DESIGN:** Model RSE-100 Distributed Power Module (Indicating Circuit Expander). Unit is power-limited and consists of an enclosure, printed circuit board, terminal boards, end-of-line resistors and two 12VDC, 7Ah rechargeable batteries. The unit provides up to 4 indicating zones and 1 auxiliary output. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Input: 120 VAC, 2A, 60 hz  
Output: 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as indicating circuit expander for use with separately listed compatible indicating devices and polarized, 24 VDC, fire alarm control unit.

**XLF:** 7300-0559:123

12-22-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 15, 2001**

*Listing Expires **June 30, 2002***

Authorized By:

**BEN HO**, Supervising Deputy  
Program Manager